
SPACE GATEWAY SUPPORT (SGS) SGS-09 65 13.13 99 (April 2006)

Preparing Activity: SGS-DE Superseding

SGS-09651J (February 2005)

SGS GUIDE SPECIFICATIONS

References are NOT in Agreement with UMRL dated 01 April 2006

Revised throughout - changes not indicated by CHG tags

SECTION TABLE OF CONTENTS

DIVISION 09 - FINISHES

SECTION 09 65 13.13 99

RESILENT BASE

04/06

- PART 1 GENERAL
 - 1.1 SUBMITTALS
 - 1.2 COLOR AND PATTERNS
- PART 2 PRODUCTS
 - 2.1 RECOMMENDED MANUFACTURER'S
 - 2.2 VINYL WALL BASE
 - 2.3 RUBBER WALL BASE
 - 2.4 ADHESIVE
 - 2.5 STAIR TREAD/RISERS
 - 2.6 PORCELAIN PAVER TILES/BASE
- PART 3 EXECUTION
 - 3.1 GENERAL
 - 3.2 APPLICATION
- -- End of Section Table of Contents --

SPACE GATEWAY SUPPORT (SGS) SGS-09 65 13.13 99 (April 2006)

Preparing Activity: SGS-DE Superseding

SGS-09651J (February 2005)

SGS GUIDE SPECIFICATIONS

References are NOT in Agreement with UMRL dated 01 April 2006

Revised throughout - changes not indicated by CHG tags

SECTION 09 65 13.13 99

RESILENT BASE 04/06

NOTE: This guide specification covers the requirements for Resilient Wall Base and Resilient Stair Treads.

Brackets are used in the text to indicate designer choices or locations where text must be supplied by the designer.

PART 1 GENERAL

1.1 SUBMITTALS

NOTE: Review submittal description (SD) definitions in Section 01 33 00 SUBMITTAL PROCEDURES and edit the following list to reflect only the submittals required for the project. Submittals should be kept to the minimum required for adequate quality control. Include a columnar list of appropriate products and tests beneath each submittal description.

A "G" following a submittal item indicates that the submittal requires Government approval. Some submittals are already marked with a "G". Only delete an existing "G" if the submittal item is not complex and can be reviewed through the Contractor's Quality Control system. Only add a "G" if the submittal is sufficiently important or complex in context of the project.

For submittals requiring Government approval on Army projects, a code of up to three characters within the submittal tags may be used following the "G" designation to indicate the approving authority. Codes for Army projects using the Resident Management System (RMS) are: "AE" for Architect-Engineer; "DO" for District Office

(Engineering Division or other organization in the District Office); "AO" for Area Office; "RO" for Resident Office; and "PO" for Project Office. Codes following the "G" typically are not used for Navy, Air Force, and NASA projects.

Submittal items not designated with a "G" are considered as being for information only for Army projects and for Contractor Quality Control approval for Navy, Air Force, and NASA projects.

The following shall be submitted in accordance with Section 01 33 00 SUBMITTAL PROCEDURES in sufficient detail to show full compliance with the specification:

SD-03 Product Data

Manufacturer's Product Data and installation instructions as well as maintenance instructions.

SD-04 Samples

Samples of type, color and pattern of wall base.

1.2 COLOR AND PATTERNS

As shown or scheduled on drawings. Submit samples of each product type, color and pattern for review and approval.

PART 2 PRODUCTS

2.1 RECOMMENDED MANUFACTURER'S

Armstrong World Industries, Inc. American Floor Products Co. Inc. Endura Rubber Flooring Crossfield Products, Inc.

2.2 VINYL WALL BASE

Fed. Spec. SS-W-40A, Notice 1(7 Jun 74), Type II; 4 inches high, 0.080 inch gauge; with matching end stops and preformed corner units; standard top-set cove. Provide three copies of Product Data.

2.3 RUBBER WALL BASE

Fed. Spec. SS-W-40A, Notice 1(7 June 74), Type II; 4 inches high, 1/8 inch gauge; with matching end stops and preformed corner units; standard top-set cove.

2.4 ADHESIVE

As recommended by the manufacturer.

2.5 STAIR TREAD/RISERS

Provide resilient stair treads as manufactured by the following:

DAP, Inc.
Burke Flooring Products
Advanced Polymer Technology Corporation

2.6 PORCELAIN PAVER TILES/BASE

Provide ceramic tiles in $4" \times 4"$ and other sizes as manufactured by the following:

Interceramic, USA American Olean DATILE

PART 3 EXECUTION

3.1 GENERAL

Prior to installation, ensure that surfaces are clean, thoroughly dry, smooth, firm and sound and free from springiness, oil, paint, wax, dirt or any other damaging material.

3.2 APPLICATION

Provide wall base as specified herein. Apply wall base in accordance with the installation instructions. Perform work by personnel thoroughly experienced in the application of such flooring.

Adhesives: Apply adhesives in accordance with the adhesive manufacturer's printed directions, unless specified or directed otherwise. Smoking, the use of open flames, and other immediate sources of ignition are strictly prohibited in the area where adhesives are being used or spread. Post conspicuous signs regarding NO SMOKING OR OPEN FLAME in the area where adhesives are being spread.

Wall base: Apply wall base after installation of wallcovering has been completed and the wall surface to which the base is to be applied is thoroughly dry. Apply special base adhesive to the back of the base with a notched trowel, leaving approximately 1/4 inch bare space along the top edge of the base. Immediately press the base firmly against the wall and move gently into place, making sure that the toe is in contact with the floor surface and the wall. Roll the entire surface of the base with a hand roller and press the toe of the base firmly against the wall with a straight piece of wood. Clean after installation.

Fill cracks and voids in the wall with a crack filler as specified for this application. Bring irregular surfaces to a smooth finish with a smoothing compound.

Cleaning: Immediately upon completion of the installation in a room or area, dry-clean wall base surfaces with a cleaner to remove surplus adhesive. Provide three copies of manufacturer's maintenance instructions.

Finishing: Clean bases but do not polish.

-- End of Section --